

Water Sanitation Comparison Chart

| | Stabilized peroxide | Chlorine | Chlorine dioxide |
|-----------------------------|---------------------|-------------------------|-------------------|
| Biofilm degradation | ✓ | | ✓ |
| pH dependency | none | More active at lower pH | active at pH 2-10 |
| Corrosive to piping systems | possible | ✓ | |
| Water odour | Negative impact | Negative impact | No impact |
| Water taste | Negative impact | Negative impact | No impact |